Certificate of Compliance

Awarded to:

Colder Products Company 504 Malcolm Avenue SE, Suite 900 Minneapolis, MN 55414

The following rooms MET the requirements of ISO 14644-1:2015

at 0.5 and 5.0 micron in the operational mode on

18 APR 2022

MICHAEL H. TURNURE CERTIFICATION 3635
Exp. 3/31/23

Room Name	ISO Class
Gowning	ISO Class 7
Production	ISO Class 7
In/Staging	ISO Class 7
Kitting/Material Transfer	ISO Class 7

Out ISO Class 7

Pace Analytical SECENTIFIC PROFESSIONAL SERVICES

Mike Turnure

Pace Analytical Services, LLC Cleanroom Qualification Program Manager LabOps Instrument Support Group (ISG)